

CERTIFICATE

Test of a fire extinguisher in accordance with EN3-7

Model PA 6

Drawing no. 137.00.00 dated on 05.04

of company: **VALPRO Corporation**
L. Laicena Str. 2
LV 4201, Valmiera
LATVIA

Laboratory:

MPA Dresden GmbH

Official Laboratory for fire extinguishing media and fire extinguishers
Fuchsmühlenweg 6F
09599 Freiberg
GERMANY

This is to certify conformity of the tested fire extinguisher model PA 6 with the requirements of the European Standard EN 3-7 : 2004-1.

Fire performance: 34 A and 233 B

Operating temperature range: - 30 °C to + 60 °C

Basis of this confirmation is the laboratory report no. 04-6-1295/V 01.

2nd March 2005



Grad. Eng. Hübner
Head of the department
Fire Protection



Grad. Eng. Dittrich
Laboratory Manager