

CERTIFICATE

Test of a fire extinguisher in accordance with EN 3

6 kg ABC powder fire extinguisher

Model PA 6 S

Drawing No. 137.00.00 ST

of company: **VALPRO Ltd.,**
L. Laicena str. 2
LV-4201 Valmiera, LATVIA

Test laboratory:

MPA Dresden GmbH
Official Laboratory for fire extinguishing media and fire extinguishers
Fuchsmühlenweg 6F
09599 Freiberg, GERMANY

This is to certify conformity of the tested fire extinguisher model PA6S with the requirements of the European Standard EN 3-7 : 2007-08.

Fire performance: 34 A and 183 B

Operation temperature range: - 30 °C to + 60 °C

Basis of this confirmation is the test report No. 04-6-1295/V 01 dated 2005-01-31 in conjunction with the supplement No. 2009-F-3055/V 11 dated 2009-12-15.

15th December 2009



Grad. Eng. Dittrich
Laboratory Manager



MPA Dresden GmbH
Fuchsmühlenweg 6F
D-09599 Freiberg
Tel.: +49(0)3731-2 03 93-0
Fax: +49(0)3731-2 03 93-110

Geschäftsführer: Thomas Hübler
Steuernummer: 220/114/03011
Amtsgericht Chemnitz HR B 21581
Internet: www.mpa-dresden.de
E-Mail: info@mpa-dresden.de

Kreissparkasse Freiberg
Poststraße 1a
D-09599 Freiberg
Kto.: 3115024672
BLZ: 870 520 00

USt-IdNr.: DE234220069
IBAN DE68 8705 2000 3115 0246 72
BIC WELADED1FGX